



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J1D1226

**Tully Central School District**

**Project Name: Jr. Sr. High School**

Jerry Bishop  
 20 State Street  
 Tully, NY 13159-0628

Project / PO Number: N/A  
 Received: 04/20/2021  
 Reported: 05/25/2021

**Analytical Testing Parameters**

<b>Client Sample ID:</b> 137A Band Hall Boy's Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:28
<b>Lab Sample ID:</b> J1D1226-01	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0271	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1345	LLW

<b>Client Sample ID:</b> 137b Band Hall Girl's Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:28
<b>Lab Sample ID:</b> J1D1226-02	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0081	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1350	LLW

<b>Client Sample ID:</b> 162 Kitchen North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:30
<b>Lab Sample ID:</b> J1D1226-03	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0239	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1352	LLW

<b>Client Sample ID:</b> 162 Kitchen Dish Rm West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:30
<b>Lab Sample ID:</b> J1D1226-04	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1354	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 162 Kitchen Dish Rm East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:30
<b>Lab Sample ID:</b> J1D1226-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0014	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1356	LLW

<b>Client Sample ID:</b> 172 Kitchen Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:30
<b>Lab Sample ID:</b> J1D1226-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0199</b>	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1403	LLW

<b>Client Sample ID:</b> 174 Boiler (As Per bottle label)	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 0:00
<b>Lab Sample ID:</b> J1D1226-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0056	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1405	LLW

<b>Client Sample ID:</b> 188 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:32
<b>Lab Sample ID:</b> J1D1226-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0010	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1407	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 188 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:32
<b>Lab Sample ID:</b> J1D1226-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0074	0.015 AL	0.0020	mg/L		05/12/21 1252	05/13/21 1152	LLW

<b>Client Sample ID:</b> 188 South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:32
<b>Lab Sample ID:</b> J1D1226-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0090	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1410	LLW

<b>Client Sample ID:</b> 194 North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:32
<b>Lab Sample ID:</b> J1D1226-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0017	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1412	LLW

<b>Client Sample ID:</b> 161A Boys Coach Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0221	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1416	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 155B West JH Boys Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0509	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1418	LLW

<b>Client Sample ID:</b> 155b East JH Boys Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0464	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1429	LLW

<b>Client Sample ID:</b> 181 North SH Boys Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0095	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1431	LLW

<b>Client Sample ID:</b> 181 Center SH Boys Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0082	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1432	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 181 South SH Boys Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:33
<b>Lab Sample ID:</b> J1D1226-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0071	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1434	LLW

<b>Client Sample ID:</b> Sport South Wing Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:34
<b>Lab Sample ID:</b> J1D1226-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0064	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1436	LLW

<b>Client Sample ID:</b> Sport South Wing Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:34
<b>Lab Sample ID:</b> J1D1226-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0028	0.015 AL	0.0010	mg/L		05/12/21 1252	05/12/21 1438	LLW

<b>Client Sample ID:</b> 175 South SH Girls Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:35
<b>Lab Sample ID:</b> J1D1226-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0145	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1540	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 175 North SH Girls Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:35
<b>Lab Sample ID:</b> J1D1226-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0143	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1447	LLW

<b>Client Sample ID:</b> 145a West JH Girls Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:35
<b>Lab Sample ID:</b> J1D1226-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0233</b>	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1453	LLW

<b>Client Sample ID:</b> 145A East JH Girls Locker	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:35
<b>Lab Sample ID:</b> J1D1226-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.259</b>	0.015 AL	0.0010	mg/L		05/14/21 1436	05/17/21 1150	LLW

<b>Client Sample ID:</b> 147A Girls Coach Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:36
<b>Lab Sample ID:</b> J1D1226-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0125	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1454	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 173A SOml	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:36
<b>Lab Sample ID:</b> J1D1226-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0095	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1456	LLW

<b>Client Sample ID:</b> 169A Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:36
<b>Lab Sample ID:</b> J1D1226-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0080	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1458	LLW

<b>Client Sample ID:</b> 146 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:36
<b>Lab Sample ID:</b> J1D1226-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0199</b>	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1505	LLW

<b>Client Sample ID:</b> 146 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:37
<b>Lab Sample ID:</b> J1D1226-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1509	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 154 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:37
<b>Lab Sample ID:</b> J1D1226-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0160	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1511	LLW

<b>Client Sample ID:</b> 154 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:38
<b>Lab Sample ID:</b> J1D1226-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0068	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1513	LLW

<b>Client Sample ID:</b> 152 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:38
<b>Lab Sample ID:</b> J1D1226-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0055	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1515	LLW

<b>Client Sample ID:</b> 152 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:38
<b>Lab Sample ID:</b> J1D1226-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0116	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1516	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 148 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:39
<b>Lab Sample ID:</b> J1D1226-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0075	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1520	LLW

<b>Client Sample ID:</b> 148 Center	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:39
<b>Lab Sample ID:</b> J1D1226-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0074	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1527	LLW

<b>Client Sample ID:</b> 148 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:39
<b>Lab Sample ID:</b> J1D1226-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0246</b>	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1529	LLW

<b>Client Sample ID:</b> 146 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:40
<b>Lab Sample ID:</b> J1D1226-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0167</b>	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1531	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> East Art Hall Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:40
<b>Lab Sample ID:</b> J1D1226-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1533	LLW

<b>Client Sample ID:</b> West Art Hall Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:41
<b>Lab Sample ID:</b> J1D1226-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1535	LLW

<b>Client Sample ID:</b> Erst Art Hall Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:41
<b>Lab Sample ID:</b> J1D1226-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1537	LLW

<b>Client Sample ID:</b> Center West Art Hall Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:41
<b>Lab Sample ID:</b> J1D1226-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1433	05/12/21 1538	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> Center East Art Hall Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:42
<b>Lab Sample ID:</b> J1D1226-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1551	LLW

<b>Client Sample ID:</b> East Art Hall Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:42
<b>Lab Sample ID:</b> J1D1226-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1557	LLW

<b>Client Sample ID:</b> 136 Mail Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:44
<b>Lab Sample ID:</b> J1D1226-49	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0102	0.015 AL	0.0102	mg/L		05/12/21 1439	05/13/21 1211	LLW

<b>Client Sample ID:</b> 136D Main Office Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:44
<b>Lab Sample ID:</b> J1D1226-50	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0403	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1600	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 132A Nurse Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:44
<b>Lab Sample ID:</b> J1D1226-51	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0156	0.015 AL	0.0051	mg/L		05/12/21 1439	05/13/21 1213	LLW

<b>Client Sample ID:</b> 108A Faculty Mens Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:44
<b>Lab Sample ID:</b> J1D1226-52	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0102	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1610	LLW

<b>Client Sample ID:</b> 108b Faculty Womens Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:45
<b>Lab Sample ID:</b> J1D1226-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0148	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1611	LLW

<b>Client Sample ID:</b> 110 AV Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:46
<b>Lab Sample ID:</b> J1D1226-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0270	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1613	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 112a 1st FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:47
<b>Lab Sample ID:</b> J1D1226-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0020	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1615	LLW

<b>Client Sample ID:</b> 112B 1st FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:47
<b>Lab Sample ID:</b> J1D1226-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0035	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1617	LLW

<b>Client Sample ID:</b> 112C 1st FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:47
<b>Lab Sample ID:</b> J1D1226-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0094	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1619	LLW

<b>Client Sample ID:</b> 112D 1st FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:47
<b>Lab Sample ID:</b> J1D1226-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0121	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1622	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 112E 1st FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:47
<b>Lab Sample ID:</b> J1D1226-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0039	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1624	LLW

<b>Client Sample ID:</b> 114a 1st FL Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:48
<b>Lab Sample ID:</b> J1D1226-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1626	LLW

<b>Client Sample ID:</b> 114E 1st FL Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:48
<b>Lab Sample ID:</b> J1D1226-64	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1633	LLW

<b>Client Sample ID:</b> 128 Teachers Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:50
<b>Lab Sample ID:</b> J1D1226-65	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0071	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1635	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 128 A East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:50
<b>Lab Sample ID:</b> J1D1226-66	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0015	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1637	LLW

<b>Client Sample ID:</b> 128 A West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:50
<b>Lab Sample ID:</b> J1D1226-67	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0090	0.015 AL	0.0010	mg/L		05/12/21 1439	05/12/21 1639	LLW

<b>Client Sample ID:</b> 128 B West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:50
<b>Lab Sample ID:</b> J1D1226-69	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/12/21 1439	05/13/21 1207	LLW

<b>Client Sample ID:</b> 128 C South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:51
<b>Lab Sample ID:</b> J1D1226-70	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		05/12/21 1439	05/13/21 1209	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 128 C North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:51
<b>Lab Sample ID:</b> J1D1226-71	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1415	LLW

<b>Client Sample ID:</b> 128 D South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:51
<b>Lab Sample ID:</b> J1D1226-72	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0028	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1421	LLW

<b>Client Sample ID:</b> 128 D North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:51
<b>Lab Sample ID:</b> J1D1226-73	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0028	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1422	LLW

<b>Client Sample ID:</b> 128 E East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:51
<b>Lab Sample ID:</b> J1D1226-74	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0021	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1424	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 128 E West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:52
<b>Lab Sample ID:</b> J1D1226-75	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0031	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1426	LLW

<b>Client Sample ID:</b> 128 G East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:52
<b>Lab Sample ID:</b> J1D1226-77	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1428	LLW

<b>Client Sample ID:</b> 128 G West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:52
<b>Lab Sample ID:</b> J1D1226-78	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1433	LLW

<b>Client Sample ID:</b> 128 Back Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:52
<b>Lab Sample ID:</b> J1D1226-79	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0032	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1435	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 129 TEacheres Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:54
<b>Lab Sample ID:</b> J1D1226-80	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0518	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1437	LLW

<b>Client Sample ID:</b> 129 East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:54
<b>Lab Sample ID:</b> J1D1226-81	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0129	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1439	LLW

<b>Client Sample ID:</b> 129 South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:54
<b>Lab Sample ID:</b> J1D1226-82	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0087	0.015 AL	0.0020	mg/L	D	05/14/21 1436	05/18/21 1104	LLW

<b>Client Sample ID:</b> 129 West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:55
<b>Lab Sample ID:</b> J1D1226-83	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0060	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1441	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 129 Back Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:55
<b>Lab Sample ID:</b> J1D1226-84	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1444	LLW

<b>Client Sample ID:</b> 130A Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:00
<b>Lab Sample ID:</b> J1D1226-85	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1446	LLW

<b>Client Sample ID:</b> 130D Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:01
<b>Lab Sample ID:</b> J1D1226-88	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1448	LLW

<b>Client Sample ID:</b> 130E Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:01
<b>Lab Sample ID:</b> J1D1226-89	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1450	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 205A Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:01
<b>Lab Sample ID:</b> J1D1226-90	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1455	LLW

<b>Client Sample ID:</b> 204 Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:01
<b>Lab Sample ID:</b> J1D1226-91	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0106	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1457	LLW

<b>Client Sample ID:</b> 207 Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:02
<b>Lab Sample ID:</b> J1D1226-92	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0168</b>	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1459	LLW

<b>Client Sample ID:</b> 208A 2nd FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:02
<b>Lab Sample ID:</b> J1D1226-93	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1501	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 208c 2nd FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:02
<b>Lab Sample ID:</b> J1D1226-95	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		05/13/21 1300	05/13/21 1503	LLW

<b>Client Sample ID:</b> 208D 2nd FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:03
<b>Lab Sample ID:</b> J1D1226-96	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0133	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1512	LLW

<b>Client Sample ID:</b> 208E 2nd FL Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:03
<b>Lab Sample ID:</b> J1D1226-97	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0061	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1517	LLW

<b>Client Sample ID:</b> 212B 2nd FL Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:03
<b>Lab Sample ID:</b> J1D1226-99	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0051	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1519	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 212C 2nd FL Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:04
<b>Lab Sample ID:</b> J1D1226-AA	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0170	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1521	LLW

<b>Client Sample ID:</b> 212e 2nd FL Girls Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:04
<b>Lab Sample ID:</b> J1D1226-AC	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0025	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1523	LLW

<b>Client Sample ID:</b> 217 Faculty WOMens Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:05
<b>Lab Sample ID:</b> J1D1226-AD	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1525	LLW

<b>Client Sample ID:</b> 219 Faculty Mens Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:05
<b>Lab Sample ID:</b> J1D1226-AE	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0066	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1530	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 216 Teachers Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:05
<b>Lab Sample ID:</b> J1D1226-AF	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0169	0.015 AL	0.0051	mg/L	D	05/13/21 1302	05/14/21 1506	LLW

<b>Client Sample ID:</b> 216 South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:06
<b>Lab Sample ID:</b> J1D1226-AG	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0141	0.015 AL	0.0102	mg/L	D	05/13/21 1302	05/14/21 1519	LLW

<b>Client Sample ID:</b> 216 Center	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:06
<b>Lab Sample ID:</b> J1D1226-AH	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0289	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1536	LLW

<b>Client Sample ID:</b> 216 North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:06
<b>Lab Sample ID:</b> J1D1226-AI	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0026	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1537	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 216 Lab Island	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:06
<b>Lab Sample ID:</b> J1D1226-AJ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0058	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1541	LLW

<b>Client Sample ID:</b> 216A West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:07
<b>Lab Sample ID:</b> J1D1226-AK	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0024	0.015 AL	0.0020	mg/L	D	05/13/21 1302	05/14/21 1522	LLW

<b>Client Sample ID:</b> 216A East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:07
<b>Lab Sample ID:</b> J1D1226-AL	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1545	LLW

<b>Client Sample ID:</b> 223 Teachers Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:07
<b>Lab Sample ID:</b> J1D1226-AM	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0204	0.015 AL	0.0204	mg/L	D	05/13/21 1302	05/17/21 1217	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 223 South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:07
<b>Lab Sample ID:</b> J1D1226-AN	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1552	LLW

<b>Client Sample ID:</b> 223 South East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:08
<b>Lab Sample ID:</b> J1D1226-AO	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1554	LLW

<b>Client Sample ID:</b> 223 North East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:08
<b>Lab Sample ID:</b> J1D1226-AP	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0203</b>	0.015 AL	0.0051	mg/L	D	05/13/21 1302	05/14/21 1541	LLW

<b>Client Sample ID:</b> 223 North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:08
<b>Lab Sample ID:</b> J1D1226-AQ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1558	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 225A Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:09
<b>Lab Sample ID:</b> J1D1226-AR	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0601	0.015 AL	0.0010	mg/L		05/13/21 1302	05/13/21 1559	LLW

<b>Client Sample ID:</b> 225 North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:09
<b>Lab Sample ID:</b> J1D1226-AT	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0076	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1609	LLW

<b>Client Sample ID:</b> 225 South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:10
<b>Lab Sample ID:</b> J1D1226-AU	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.121	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1614	LLW

<b>Client Sample ID:</b> 224 Teacher Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:10
<b>Lab Sample ID:</b> J1D1226-AV	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0086	0.015 AL	0.0010	mg/L		05/13/21 1407	05/14/21 1544	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 224 East A	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:10
<b>Lab Sample ID:</b> J1D1226-AW	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0514	0.015 AL	0.0010	mg/L		05/14/21 1436	05/17/21 1152	LLW

<b>Client Sample ID:</b> 224 East B	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:11
<b>Lab Sample ID:</b> J1D1226-AX	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0926	0.015 AL	0.0010	mg/L		05/14/21 1436	05/17/21 1153	LLW

<b>Client Sample ID:</b> 224 West A	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:12
<b>Lab Sample ID:</b> J1D1226-BA	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0110	0.015 AL	0.0010	mg/L	H5	05/14/21 1140	05/14/21 1212	LLW

<b>Client Sample ID:</b> 224 West B	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:12
<b>Lab Sample ID:</b> J1D1226-BB	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1618	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 224 West C	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:12
<b>Lab Sample ID:</b> J1D1226-BC	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0226	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1620	LLW

<b>Client Sample ID:</b> 224 Back Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:13
<b>Lab Sample ID:</b> J1D1226-BD	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0108	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1621	LLW

<b>Client Sample ID:</b> 226a Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:13
<b>Lab Sample ID:</b> J1D1226-BE	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0092	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1627	LLW

<b>Client Sample ID:</b> 226B Boys LAV	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:13
<b>Lab Sample ID:</b> J1D1226-BF	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0147	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1629	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 226E Boys Lav	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:13
<b>Lab Sample ID:</b> J1D1226-BI	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0069	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1631	LLW

<b>Client Sample ID:</b> 223 Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:13
<b>Lab Sample ID:</b> J1D1226-BJ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1632	LLW

<b>Client Sample ID:</b> 231 Teachers Desk	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BK	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0062	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1634	LLW

<b>Client Sample ID:</b> 231A East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BL	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0074	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1638	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 231A West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BM	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0054	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1640	LLW

<b>Client Sample ID:</b> 231B Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BN	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1642	LLW

<b>Client Sample ID:</b> 231C East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BO	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0259</b>	0.015 AL	0.0020	mg/L	D	05/13/21 1407	05/14/21 1555	LLW

<b>Client Sample ID:</b> 231C West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:14
<b>Lab Sample ID:</b> J1D1226-BP	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0172</b>	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1649	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 231e South	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:15
<b>Lab Sample ID:</b> J1D1226-BS	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0096	0.015 AL	0.0050	mg/L	D	05/14/21 1436	05/18/21 1113	LLW

<b>Client Sample ID:</b> 231E North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:15
<b>Lab Sample ID:</b> J1D1226-BT	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0031	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1651	LLW

<b>Client Sample ID:</b> 231F East	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:15
<b>Lab Sample ID:</b> J1D1226-BU	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0066	0.015 AL	0.0020	mg/L	D	05/13/21 1407	05/14/21 1601	LLW

<b>Client Sample ID:</b> 231F West	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:15
<b>Lab Sample ID:</b> J1D1226-BV	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0106	0.015 AL	0.0010	mg/L		05/13/21 1407	05/13/21 1654	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 231 Back Room	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:16
<b>Lab Sample ID:</b> J1D1226-BY	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0269	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1729	LLW

<b>Client Sample ID:</b> ICe Machine	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:17
<b>Lab Sample ID:</b> J1D1226-BZ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0035	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1733	LLW

<b>Client Sample ID:</b> 1st FL T NORTH Drinking Fountain	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:17
<b>Lab Sample ID:</b> J1D1226-CB	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1735	LLW

<b>Client Sample ID:</b> 2nd FL South Drinking Fountain	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:17
<b>Lab Sample ID:</b> J1D1226-CC	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1737	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> Main Entrance North Drinking Fountain	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:18
<b>Lab Sample ID:</b> J1D1226-CF	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L	H5	05/14/21 1140	05/14/21 1256	LLW

<b>Client Sample ID:</b> Boiler Room Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:21
<b>Lab Sample ID:</b> J1D1226-CJ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1738	LLW

<b>Client Sample ID:</b> 167 Ice RM Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:22
<b>Lab Sample ID:</b> J1D1226-CK	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0055	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1744	LLW

<b>Client Sample ID:</b> 196 Sport Hall Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:22
<b>Lab Sample ID:</b> J1D1226-CL	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0049	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1746	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

<b>Client Sample ID:</b> 142 Art Hall Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:23
<b>Lab Sample ID:</b> J1D1226-CM	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1748	LLW

<b>Client Sample ID:</b> 112A T Hall Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:24
<b>Lab Sample ID:</b> J1D1226-CN	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0087	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1749	LLW

<b>Client Sample ID:</b> 126 Science Hall Mop Sink	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:24
<b>Lab Sample ID:</b> J1D1226-CO	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0052	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1751	LLW

<b>Client Sample ID:</b> 210 2nd FL North	<b>Collected By:</b> Vince Case
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2021 6:25
<b>Lab Sample ID:</b> J1D1226-CP	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0104	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1726	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1D1226

Client Sample ID: 222 2nd FL South	Collected By: Vince Case
Sample Matrix: Drinking Water	Collection Date: 04/20/2021 6:25
Lab Sample ID: J1D1226-CQ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<b>0.0190</b>	0.015 AL	0.0010	mg/L		05/13/21 1410	05/13/21 1727	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- H5: Sample was preserved past holding time.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 05/25/2021 10:00



Tully Central School District  
PM: Shannon Weeks

Customer: Tully Central Schools  
Contact: Vince Case  
Project: Lead in Water

Sampled By: Vince Case  
Sampler Phone #: 315-256-6367

School County: Onondaga  
School Type: High School  
School Name: Jr. Sr. High School  
School ID:  
Sampling Event Name: Lead Testing in School Drinking Water  
Building address: 20 Slate Street, Tully NY  
Building ID:



Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Use	Fixture Area Type	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		137A	Band Hall Boy's LAV	1	4/19/2021		4/20/2021	6:28	X
2		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		137B	Band Hall Girls LAV	1	4/19/2021		4/20/2021	6:28	X
3		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		162	Kitchen North	1	4/19/2021		4/20/2021	6:30	X
4		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		162	Kitchen Dish Rm West	1	4/19/2021		4/20/2021	6:30	X
5		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		162	Kitchen Dish Rm East	1	4/19/2021		4/20/2021	6:30	X
6		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		172	Kitchen LAV	1	4/19/2021		4/20/2021	6:30	X
7		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption	Did Not Sample	174	Boiler Rm Lav	1	4/19/2021		4/20/2021		X
8		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		188	West	1	4/19/2021		4/20/2021	6:32	X
9		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		188	East	1	4/19/2021		4/20/2021	6:32	X
10		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		188	South	1	4/19/2021		4/20/2021	6:32	X
11		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		194	North	1	4/19/2021		4/20/2021	6:32	X
12		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		161A	Boys Coach Lav	1	4/19/2021		4/20/2021	6:33	X
13		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption	Did Not Sample	159	Boys Coach Storage	1	4/19/2021		4/20/2021		X
14		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		155B	West JH Boys Locker	1	4/19/2021		4/20/2021	6:33	X
15		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		155B	East JH Boys Locker	1	4/19/2021		4/20/2021	6:33	X
16		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		181	North SH Boys Locker	1	4/19/2021		4/20/2021	6:33	X
17		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		181	Center SH Boys Locker	1	4/19/2021		4/20/2021	6:33	X
18		FIRST DRAW	Jr-Sr High School	Faucet, Cold	Consumption		181	South SH Boys Locker	1	4/19/2021		4/20/2021	6:33	X

19	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	Sport	North Wing Boys Lav	1	4/19/2021	4/20/2021	X
20	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		Sport	South Wing Boys Lav	1	4/19/2021	4/20/2021	6:34 X
21	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		Sport	South Wing Girls Lav	1	4/19/2021	4/20/2021	6:34 X
22	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	Sport	North Wing Girls Lav	1	4/19/2021	4/20/2021	X
23	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		175	South SH Girls Locker	1	4/19/2021	4/20/2021	6:35 X
24	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	175	Center SH Girls Locker	1	4/19/2021	4/20/2021	X
25	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		175	North SH Girls Locker	1	4/19/2021	4/20/2021	6:35 X
26	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		145A	West JH Girls Locker	1	4/19/2021	4/20/2021	6:35 X
27	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		145A	East JH Girls Locker	1	4/19/2021	4/20/2021	6:35 X
28	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		147A	Girls Coach Lav	1	4/19/2021	4/20/2021	6:36 X
29	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		173A	Sink	1	4/19/2021	4/20/2021	6:36 X
30	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		169A	Sink	1	4/19/2021	4/20/2021	6:36 X
31	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		146	West	1	4/19/2021	4/20/2021	6:36 X
32	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		146	East	1	4/19/2021	4/20/2021	6:37 X
33	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		154	West	1	4/19/2021	4/20/2021	6:37 X
34	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		154	East	1	4/19/2021	4/20/2021	6:38 X
35	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		152	East	1	4/19/2021	4/20/2021	6:38 X
36	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		152	West	1	4/19/2021	4/20/2021	6:38 X
37	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		148	East	1	4/19/2021	4/20/2021	6:39 X
38	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		148	Center	1	4/19/2021	4/20/2021	6:39 X
39	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		148	West	1	4/19/2021	4/20/2021	6:39 X
40	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		146	West	1	4/19/2021	4/20/2021	6:40 X
41	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		East	Art Hall Girls Lav	1	4/19/2021	4/20/2021	6:40 X

42	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	Center East	Art Hall Girls Lav	1	4/19/2021	4/20/2021	X
43	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	Center West	Art Hall Girls Lav	1	4/19/2021	4/20/2021	X
44	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		West	Art Hall Girls Lav	1	4/19/2021	4/20/2021	6:41 X
45	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		West	Art Hall Boys Lav	1	4/19/2021	4/20/2021	6:41 X
46	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		Center West	Art Hall Boys Lav	1	4/19/2021	4/20/2021	6:41 X
47	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		Center East	Art Hall Boys Lav	1	4/19/2021	4/20/2021	6:42 X
48	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		East	Art Hall Boys Lav	1	4/19/2021	4/20/2021	6:42 X
49	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		135	Mall Room	1	4/19/2021	4/20/2021	6:44 X
50	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		136D	Main Office Lav	1	4/19/2021	4/20/2021	6:44 X
51	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		132A	Nurse Lav	1	4/19/2021	4/20/2021	6:44 X
52	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		108A	Faculty Mens Lav	1	4/19/2021	4/20/2021	6:44 X
53	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		108B	Faculty Womens Lav	1	4/19/2021	4/20/2021	6:45 X
54	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		110	AV Room	1	4/19/2021	4/20/2021	6:46 X
55	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		112A	1st FL Boys Lav	1	4/19/2021	4/20/2021	6:47 X
56	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		112B	1st FL Boys Lav	1	4/19/2021	4/20/2021	6:47 X
57	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		112C	1st FL Boys Lav	1	4/19/2021	4/20/2021	6:47 X
58	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		112D	1st FL Boys Lav	1	4/19/2021	4/20/2021	6:47 X
59	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		112E	1st FL Boys Lav	1	4/19/2021	4/20/2021	6:47 X
60	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		114A	1st FL Girls Lav	1	4/19/2021	4/20/2021	6:48 X
61	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		114B	1st FL Girls Lav	1	4/19/2021	4/20/2021	6:48 X
62	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		114C	1st FL Girls Lav	1	4/19/2021	4/20/2021	6:48 X
63	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		114D	1st FL Girls Lav	1	4/19/2021	4/20/2021	6:48 X
64	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		114E	1st FL Girls Lav	1	4/19/2021	4/20/2021	6:48 X

65	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	Teachers Desk	1	4/19/2021	4/20/2021	6:50	X
66	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	A East	1	4/19/2021	4/20/2021	6:50	X
67	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	A West	1	4/19/2021	4/20/2021	6:50	X
68	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	B East	1	4/19/2021	4/20/2021	6:50	X
69	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	B West	1	4/19/2021	4/20/2021	6:50	X
70	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	C South	1	4/19/2021	4/20/2021	6:51	X
71	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	C North	1	4/19/2021	4/20/2021	6:51	X
72	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	D South	1	4/19/2021	4/20/2021	6:51	X
73	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	D North	1	4/19/2021	4/20/2021	6:51	X
74	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	E East	1	4/19/2021	4/20/2021	6:51	X
75	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	E West	1	4/19/2021	4/20/2021	6:52	X
76	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	F	1	4/19/2021	4/20/2021	6:52	X
77	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	G East	1	4/19/2021	4/20/2021	6:52	X
78	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	G West	1	4/19/2021	4/20/2021	6:52	X
79	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		128	Back Room	1	4/19/2021	4/20/2021	6:52	X
80	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		129	Teachers Desk	1	4/19/2021	4/20/2021	6:54	X
81	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		129	East	1	4/19/2021	4/20/2021	6:54	X
82	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		129	South	1	4/19/2021	4/20/2021	6:54	X
83	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		129	West	1	4/19/2021	4/20/2021	6:55	X
84	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		129	Back Room	1	4/19/2021	4/20/2021	6:55	X
85	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		130A	Girls Lav	1	4/19/2021	4/20/2021	6:00	X
86	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		130B	Girls Lav	1	4/19/2021	4/20/2021	6:00	X
87	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		130C	Girls Lav	1	4/19/2021	4/20/2021	6:00	X

88	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		130D	Girls Lav	1	4/19/2021	4/20/2021	6:01	X
89	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		130E	Girls Lav	1	4/19/2021	4/20/2021	6:01	X
90	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		205A	Sink	2	4/19/2021	4/20/2021	6:01	X
91	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		204	Sink	2	4/19/2021	4/20/2021	6:01	X
92	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		207	Sink	2	4/19/2021	4/20/2021	6:02	X
93	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		208A	2nd FL Boys Lav	2	4/19/2021	4/20/2021	6:02	X
94	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		208B	2nd FL Boys Lav	2	4/19/2021	4/20/2021	6:02	X
95	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		208C	2nd FL Boys Lav	2	4/19/2021	4/20/2021	6:02	X
96	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		208D	2nd FL Boys Lav	2	4/19/2021	4/20/2021	6:03	X
97	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		208E	2nd FL Boys Lav	2	4/19/2021	4/20/2021	6:03	X
98	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		212A	2nd FL Girls Lav	2	4/19/2021	4/20/2021	6:03	X
99	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		212B	2nd FL Girls Lav	2	4/19/2021	4/20/2021	6:03	X
100	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		212C	2nd FL Girls Lav	2	4/19/2021	4/20/2021	6:04	X
101	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		212D	2nd FL Girls Lav	2	4/19/2021	4/20/2021	6:04	X
102	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		212E	2nd FL Girls Lav	2	4/19/2021	4/20/2021	6:04	X
103	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		217	Faculty Womens Lav	2	4/19/2021	4/20/2021	6:05	X
104	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		219	Faculty Mens Lav	2	4/19/2021	4/20/2021	6:05	X
105	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216	Teachers Desk	2	4/19/2021	4/20/2021	6:05	X
106	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216	South	2	4/19/2021	4/20/2021	6:06	X
107	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216	Center	2	4/19/2021	4/20/2021	6:06	X
108	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216	North	2	4/19/2021	4/20/2021	6:06	X
109	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216	Lab Island	2	4/19/2021	4/20/2021	6:06	X
110	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216A	West	2	4/19/2021	4/20/2021	6:07	X



111	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		216A	East	2	4/19/2021	4/20/2021	6:07	X
112	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		223	Teachers Desk	2	4/19/2021	4/20/2021	6:07	X
113	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		223	South	2	4/19/2021	4/20/2021	6:07	X
114	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		223	South East	2	4/19/2021	4/20/2021	6:08	X
115	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		223	North East	2	4/19/2021	4/20/2021	6:08	X
116	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		223	North	2	4/19/2021	4/20/2021	6:08	X
117	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		225A	Sink	2	4/19/2021	4/20/2021	6:09	X
118	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	225	Teachers Desk	2	4/19/2021	4/20/2021		X
119	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		225	North	2	4/19/2021	4/20/2021	6:09	X
120	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		225	South	2	4/19/2021	4/20/2021	6:10	X
121	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	Teachers Desk	2	4/19/2021	4/20/2021	6:10	X
122	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	East A	2	4/19/2021	4/20/2021	6:10	X
123	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	East B	2	4/19/2021	4/20/2021	6:11	X
124	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	224	South A	2	4/19/2021	4/20/2021		X
125	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	224	South B	2	4/19/2021	4/20/2021		X
126	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	West A	2	4/19/2021	4/20/2021	6:12	X
127	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	West B	2	4/19/2021	4/20/2021	6:12	X
128	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	West C	2	4/19/2021	4/20/2021	6:12	X
129	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		224	Back Room	2	4/19/2021	4/20/2021	6:13	X
130	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		226A	Boys Lav	2	4/19/2021	4/20/2021	6:13	X
131	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		226B	Boys Lav	2	4/19/2021	4/20/2021	6:13	X
132	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption		226C	Boys Lav	2	4/19/2021	4/20/2021	6:13	X
133	FIRST DRAW	Jr. Sr High School	Faucet, Cold	Consumption	Did Not Sample	226D	Boys Lav	2	4/19/2021	4/20/2021		X

134	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		226E	Boys Lav	2	4/19/2021	4/20/2021	6:13	X
135	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		223	Sink	2	4/19/2021	4/20/2021	6:13	X
136	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231	Teachers Desk	2	4/19/2021	4/20/2021	6:14	X
137	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231A	East	2	4/19/2021	4/20/2021	6:14	X
138	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231A	West	2	4/19/2021	4/20/2021	6:14	X
139	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231B	Sink	2	4/19/2021	4/20/2021	6:14	X
140	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231C	East	2	4/19/2021	4/20/2021	6:14	X
141	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231C	West	2	4/19/2021	4/20/2021	6:14	X
142	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	231D	South	2	4/19/2021	4/20/2021		X
143	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	231D	North	2	4/19/2021	4/20/2021		X
144	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231E	South	2	4/19/2021	4/20/2021	6:15	X
145	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231E	North	2	4/19/2021	4/20/2021	6:15	X
146	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231F	East	2	4/19/2021	4/20/2021	6:15	X
147	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231F	West	2	4/19/2021	4/20/2021	6:15	X
148	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	231G	East	2	4/19/2021	4/20/2021		X
149	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	231G	West	2	4/19/2021	4/20/2021		X
150	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		231	Back Room	2	4/19/2021	4/20/2021	6:16	X
151	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		Ice Machine	Ice Machine	2	4/19/2021	4/20/2021	6:17	X
152	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	1st FL T South	Drinking Fountain	1	4/19/2021	4/20/2021		X
153	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		1st FL T North	Drinking Fountain	1	4/19/2021	4/20/2021	6:17	X
154	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption		2nd FL South	Drinking Fountain	2	4/19/2021	4/20/2021	6:17	X
155	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	2nd FL North	Drinking Fountain	2	4/19/2021	4/20/2021		X
156	FIRST DRAW	Jr. Sr. High School	Faucet, Cold	Consumption	Did Not Sample	Main Entrance South	Drinking Fountain	1	4/19/2021	4/20/2021		X

157	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		Main Entrance North	Drinking Fountain	1	4/19/2021	4/20/2021	6:18	X
158	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption	Did Not Sample	Band Entrance	Drinking Fountain	1	4/19/2021	4/20/2021		X
159	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption	Did Not Sample	Sport Entrance East	Drinking Fountain	1	4/19/2021	4/20/2021		
160	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption	Did Not Sample	Sport Entrance West	Drinking Fountain	1	4/19/2021	4/20/2021		
161	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		Boiler Room	Mop Sink	1	4/19/2021	4/20/2021	6:21	
162	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		167	Ice RM Mop Sink	1	4/19/2021	4/20/2021	6:22	
163	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		196	Sport Hall Mop Sink	1	4/19/2021	4/20/2021	6:22	
164	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		142	Art Hall Mop Sink	1	4/19/2021	4/20/2021	6:23	
165	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		112A	"T" Hall Mop Sink	1	4/19/2021	4/20/2021	6:24	
166	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		126	Science Hall Mop Sink	2	4/19/2021	4/20/2021	6:24	
167	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		210	2nd FL North	2	4/19/2021	4/20/2021	6:25	
168	FIRST DRAW	Jr.Sr High School	Faucet, Cold	Consumption		222	2nd FL South	2	4/19/2021	4/20/2021	6:25	
169												
170												
171												
172												
173												
174												
175												
176												
177												
178												
179												







Chain of Custody

249													
250													

Sampled By (signature)	Date/Time
<i>[Signature]</i>	4/20/21 8:14 AM
Relinquished By (signature)	Date/Time
<i>[Signature]</i>	4/20/21 8:14 AM
Relinquished By (signature)	Date/Time

Received By (signature)	Date/Time
<i>[Signature]</i>	4/20/21 9:20
Received By (signature)	Date/Time
<i>[Signature]</i>	4/20/21 9:20
Received By (signature)	Date/Time

15.9 - Ice - N/A  
Therm ID: 044