

Tully Central School District
Received

NOV. 28 2018

Superintendent's Office

OCMBOCES

Committed to Your Success



Donald M. Warnow
Safety Officer
Health, Safety & Risk Management
Phone: (315) 431-8591
Fax: (315) 433-2633

MEMORANDUM

To: Rob Hughes, Superintendent, Tully Central School District
From: Donald Warnow, Safety Officer OCM BOCES *DW*
Re: Particle Counting in the Elementary and High School buildings
Date: November 26, 2018

As a standing request, I visited Tully Central on Wednesday, November 21, 2018, to conduct air sampling, as a follow up to previous testing. Because general dust is always a concern during a construction project, it was decided to perform dust sampling in various areas within the Elementary and High School buildings. These areas were chosen to correspond with previous air testing completed in the buildings.

Particulate (Dust) Sampling

Particulate testing was performed using a 'direct-read' Met-One Model 237 Laser Particle Counter to determine overall particulate levels of respirable dust within specific areas as noted in the table below. To assess the levels, the results were compared to the OSHA Permissible Exposure Limit (PEL). Typical instructional/office activities were being performed at the time of testing. The areas appeared clean and dry during my visit.

The results are as follows:

Location	Raw Count	mppcf
Elementary Lobby	50,905	.509
Elementary hall by room 39	49,888	.499
Preble Wing	41,657	.417
Elementary nurse's off.	60,657	.607
District Office lobby	43,757	.438
High School Lobby	58,035	.580
High School Conference Rm.	71,316	.713
High School Guidance	77,038	.770
High School Office	64,448	.644

* Instrument displays raw data as particles per tenth of a cubic foot of air. Raw data is multiplied by 10 to convert to particles per cubic foot of air and then divided by 1,000,000 to express as Millions of Particles Per Cubic Foot (**mppcf**) of air to allow direct comparison to OSHA limits (OSHA Table Z-3).

OSHA Permissible Exposure Limit (PEL) - Respirable Dust = 15 mppcf

Results

As shown by the test results, the particulate counts in all areas tested were well below the OSHA 15 mppcf for Respirable Dusts. These numbers are similar to the counts that were recorded when I tested previously on October 25, 2018.

Conclusions

Indoor levels are well below the legal health standards established by OSHA.

If further explanation is required, please feel free to contact me.