

# Village of Tully

5833 Meetinghouse Road  
P.O. Box 1028  
Tully, New York 13159  
Phone: 315.696.5041  
Fax: 315.696.6536  
TDD: 800.877.8339

Department of Public Works  
18 Community Drive  
Tully, New York 13159  
Phone: 315.696.5988  
Fax: 315.696.0044



<http://www.villageoftully.org>

Melissa A. Flint-Morgan  
*Mayor*

Erin C. Goodfellow  
*Deputy Mayor*

Roxanne Oliver  
Daniel Poellot  
Kathryn A. Vernay  
*Trustees*

Ruth Van Buskirk  
*Clerk-Treasurer*

September 27, 2018

Rob Hughes

Tully Central Schools

Tully, Ny 13159

Rob,

On September 24, 2018 I inspected the Tully Elementary School as the Fire Marshal for the Village of Tully. I found three minor violations that were corrected immediately. The violations were as follows. The fire extinguisher in the boiler room had a hard hat resting on it which was removed. There was a fire extinguisher that belonged to the workers sitting unsecured on the floor in the hallway by the new office. The extinguisher was moved to a safe location. The exit sign over the north west exit of the building was sitting above the ceiling tile. The workers were putting this back into place as I left. I found no other Fire Code violations during my inspection. I can be reached at 315-696-4693 if you have any further questions.

Respectfully,

A handwritten signature in black ink, appearing to read "Ralph Lamson", is written over a horizontal line.

Ralph Lamson

"Equal Opportunity and Affirmative Action Employer"